

Operational Report: Announced Allocation

Nogoa Mackenzie WSS – Tartrus Weir section

Effective: 15 July 2021

Section 8A of the Operations Manual for the Nogoa Mackenzie WSS contains critical water sharing rules for Tartrus Weir. These arrangements were triggered on 1 July 2021 since Fairbairn Dam level was below 194.11m AHD (approx 250,000ML) and the scheme AAm < 30%

	Abbreviation	Value	Unit	Remarks
Medium Priority Announced Allocation (Tartrus Weir, Zones Mackenzie B-D)	AAm ^T	30	%	
Tartrus Weir				
Elevation	EL	81.71	m AHD	
Storage Volume	CV ^T	11,848	ML	
Storage Loss	SL ^T	4,284	ML	
Dead Storage Volume	DSV ^T	2,530	ML	
Useable Volume	UV ^T	5,034	ML	
Additional Parameters				
High Priority Allocation	HPA ^T	0	ML	no HP allocations in Tartrus
Medium Priority Allocation	MPA ^T	5,364	ML	
Net carryover volume of water allocation moved into current water year	VIWY ^T	1,991	ML	
Transmission and Operational Losses	TOL ^T	439	ML	
Diversions (Usage)	DIV ^T	0	ML	