

Operational Report: Announced Allocation

Upper Condamine WSS

Effective: 1 July 2023

IMPORTANT MESSAGE REGARDING WATER AVAILABILITY

In accordance with provisions of Section 6 of the Upper Condamine Water Supply Scheme Operations Manual, the High B & Medium Priority release (cut-off) will be activated when Leslie Dam is below 460.35m AHD (15,005 ML).

When the rule is activated, this may impact on Sunwater’s ability to supply all of the announced allocation volume.

	Abbreviation	Value	Unit	Remarks
High Class A Priority AA	AAhpa	100	%	
High Class B Priority AA	AAhpb	100	%	
Medium Priority AA	AAm	100	%	
Risk Class B AA	AArb	49	%	
Leslie Dam				
Elevation	EL	471.54	m AHD	
Current Volume	CV	95,459	ML	
Current Area		1,199	ha	
Storage Loss	SL	19,875	ML	
Minimum Operating Volume	MOV	2,130	ML	
Useable Volume	UV	73,454	ML	
Cecil Plains Weir				
Elevation	EL	350.79	m AHD	
Current Volume	CV	674	ML	
Current Area		33	ha	
Storage Loss	SL	431	ML	
Minimum Operating Volume	MOV	49	ML	
Useable Volume	UV	194	ML	
Additional Parameters				
Diversion	DIV	0	ML	
Diversion for High Priority A	DIV-HPA	0	ML	
Diversion for High Priority B	DIV-HPB	0	ML	
Volume stored in Leslie Dam at SOWY	VOL	95,459	ML	
High Class A Priority Allocation	HPA	3,262	ML	
High Class B Priority Allocation	HPB	125	ML	
Medium Priority Allocation	MPA	22,328	ML	
Reserve Volume	RE	6,000	ML	
Transmission and Operation Allowance	TOAmp	11,288	ML	
TOA for delivering HPA	TOAhpa	0	ML	HPA are on-pond
FSV of Leslie Dam	FSV	106,200	ML	