

OPERATIONAL REPORT – ANNOUNCED ALLOCATION

BURDEKIN HAUGHTON WATER SUPPLY SCHEME

EFFECTIVE – 1 July 2016

| | Abbreviation | Value | Unit | Remarks | |
|---|--------------|-----------|-------|-----------------------|--------|
| High Priority Announced Allocation | AAh | 100% | % | | |
| Medium Priority Announced Allocation | AAm | 80% | % | | |
| Burdekin Falls Dam | | | | | |
| Elevation | EL | 153.24 | m AHD | | |
| Storage Volume | | 1,724,129 | ML | | |
| Storage Area | | 20,539 | ha | | |
| Storage Loss | SL | 395,374 | ML | | |
| Dead Storage Volume | DSV | 7,860 | ML | | |
| Useable Volume | UV | 1,320,895 | ML | | |
| Clare Weir | | | | | |
| Elevation | EL | 20.24 | m AHD | | |
| Storage Volume | | 14,402 | ML | | |
| Storage Area | | 452 | ha | | |
| Storage Loss | SL | 8,693 | ML | | |
| Dead Storage Volume | DSV | 10 | ML | | |
| Useable Volume | UV | 5,699 | ML | | |
| Additional Parameters | | | | | |
| High Priority Allocation | HPA | 99,998 | ML | | |
| Medium Priority Allocation | MPA | 979,594 | ML | | |
| | | | | Carry Over | 210000 |
| Inflow Allowance | IN | 0 | ML | | |
| Reserve Volume | RE | 0 | ML | | |
| Transmission and Operational Allowance | TOA | 226,731 | ML | | |
| HP Transmission and Operational Allowance | TOAH | 6,710 | | | |
| Minimum Flow Volume | MFV | 5,967 | | | |
| HP Diversions | HPD | 0 | | | |
| MP Diversions | MPD | 0 | ML | Carry Over Diversions | 0 |