

**OPERATIONAL REPORT – ANNOUNCED ALLOCATION**

**UPPER CONDAMINE WATER SUPPLY SCHEME**

**EFFECTIVE – 01 NOVEMBER 2016**

**IMPORTANT MESSAGE REGARDING WATER AVAILABILITY**

In accordance with provisions of section 165 of the Condamine Balonne ROP, the High B & Medium Priority release (cut-off) rule will be activated when Leslie Dam is equal to or below 460.35mAHD (volume 15,005ML).

If the rule is activated, this may impact on SunWater’s ability to supply all of the announced allocation volume.

	<b>Abbreviation</b>	<b>Value</b>	<b>Unit</b>	<b>Remarks</b>
High Class A Priority AA	<b>AAhpa</b>	100%	%	
High Class B Priority AA	<b>AAhpb</b>	100%	%	
Medium Priority AA	<b>AAm</b>	53%	%	
Risk Class B AA	<b>AArb</b>	N/A	%	
<b>Leslie Dam</b>				
Elevation	<b>EL</b>	464.43	m AHD	
Current Volume	<b>CV</b>	33,410	ML	
Current Area		583	ha	
Storage Loss	<b>SL</b>	6,932	ML	
Minimum Operating Volume	<b>MOV</b>	2,130	ML	
Useable Volume	<b>UV</b>	24,349	ML	
<b>Cecil Plains Weir</b>				
Elevation	<b>EL</b>	351.24	m AHD	
Current Volume	<b>CV</b>	700	ML	
Current Area		34	ha	
Storage Loss	<b>SL</b>	339	ML	
Minimum Operating Volume	<b>MOV</b>	49	ML	
Useable Volume	<b>UV</b>	312	ML	
<b>Additional Parameters</b>				
Diversion	<b>DIV</b>	311	ML	
Diversion for High Priority A	<b>DIV-HPA</b>	268	ML	
Diversion for High Priority B	<b>DIV-HPB</b>	0	ML	
Volume stored in Leslie Dam at SOWY	<b>VOL</b>	14,700	ML	
High Class A Priority Allocation	<b>HPA</b>	3,262	ML	
High Class B Priority Allocation	<b>HPB</b>	125	ML	
Medium Priority Allocation	<b>MPA</b>	22,328	ML	
Reserve Volume	<b>RE</b>	6,000	ML	
Transmission and Operation Allowance	<b>TOAmp</b>	3,456	ML	
TOA for delivering HPA	<b>TOAhp</b>	0	ML	HPA are on-pond
FSV of Leslie Dam	<b>FSV</b>	106,200	ML	