

Operational Report: Announced Allocation

Dawson Valley WSS, Upper Dawson sub-scheme

Effective: 1 October 2026

	Abbreviation	Value	Unit	Remarks
High Priority Announced Allocation	AAh	100	%	
Medium A Priority Announced Allocation	AAma	0	%	
Medium Priority Announced Allocation	AAm	0	%	
Glebe Weir				
Elevation	EL	164.67	m AHD	
Current Volume	CV	2,049	ML	
Surface Area	SA	94	ha	
Storage Loss	SL	931	ML	
Dead Storage Volume	DSV	430	ML	
Useable Volume	UV	688	ML	
Gyranda Weir				
Elevation	EL	151.89	m AHD	
Current Volume	CV	3,799	ML	
Surface Area	SA	122	ha	
Storage Loss	SL	1,210	ML	
Dead Storage Volume	DSV	2,120	ML	
Useable Volume	UV	469	ML	
Theodore Weir				
Elevation	EL	133.08	m AHD	
Current Volume	CV	4,240	ML	
Surface Area	SA	93	ha	
Storage Loss	SL	919	ML	
Dead Storage Volume	DSV	750	ML	
Useable Volume	UV	2,571	ML	
Moura Offstream Storage				
Elevation	EL	119.68	m AHD	
Current Volume	CV	306	ML	
Surface Area	SA	19	ha	
Storage Loss	SL	189	ML	
Dead Storage Volume	DSV	140	ML	
Useable Volume	UV	0	ML	
Moura Weir				
Elevation	EL	102.04	m AHD	
Current Volume	CV	3,671	ML	
Surface Area	SA	100	ha	
Storage Loss	SL	988	ML	
Dead Storage Volume	DSV	599	ML	
Useable Volume	UV	2,083	ML	

	Abbreviation	Value	Unit	Remarks
Additional Parameters				
High Priority Allocation	HPA	4,581	ML	
Medium A Priority Allocation	MAPA	19,276	ML	
Medium Priority Allocation	MPA	29,519	ML	
Total Usable Volume	UV	5,812	ML	
Net Carryover Volume	VIWY	4,493	ML	Carryover
				Carryover Diversions
Inflow Allowance	IN	2,500	ML	4,493 ¹
Inflow of treated CSG	INCSG	221	ML	0
Reserve Volume	RE	2,500	ML	
Transmission and Operational Losses	TOL	250	ML	
Unsupplemented use of treated CSG	UCSG	0	ML	
Diversions	DIV	0	ML	

Note 1: Carryover volume calculated as 4,493 ML. An additional assumed useable volume of 2,640 ML from Orange Creek Weir is to be made available to support carryover volume. Water balance provided below:

Carryover water balance

	Abbreviation	Value	Unit	Remarks
Usable volume in storage	UV	6,463	m AHD	Using 08.10.2026 levels
<i>Plus</i> Inflow Allowance	IN	2,500	ML	
<i>Plus</i> Inflow of treated CSG	INCSG	221	ML	
<i>Minus</i> Reserve Volume	RE	2,500	ML	
<i>Minus</i> Transmission and Operational Losses	TOL	250	ML	
<i>Minus</i> High Priority Allocation	HPA	4,581	ML	
<i>Plus</i> Useable volume from Orange Creek Weir		2,640	ML	
<i>Equals</i> Volume available for carryover		4,493	ML	