

Operational Report: Announced Allocation

Nogoa Mackenzie WSS

Effective: 1 October 2021

	Abbreviation	Value	Unit	Remarks
High Priority Announced Allocation	AAh	100	%	
Medium Priority Announced Allocation	AAm	0	%	
Fairbairn Dam				
Elevation	EL	192.92	m AHD	
Storage Volume		179,737	ML	
Storage Area		5,483	ha	
Storage Loss	SL	73,471	ML	
Dead Storage Volume	DSV	12,300	ML	
Useable Volume	UV	93,965	ML	
Bedford Weir				
Elevation	EL	122.60	m AHD	
Storage Volume		17,231	ML	
Storage Area		356	ha	
Storage Loss	SL	5,051	ML	
Dead Storage Volume	DSV	3,290	ML	
Useable Volume	UV	8,890	ML	
Bingegang Weir				
Elevation	EL	102.06	m AHD	
Storage Volume		6,198	ML	
Storage Area		196	ha	
Storage Loss	SL	2,784	ML	
Dead Storage Volume	DSV	1,400	ML	
Useable Volume	UV	2,015	ML	
Tartus Weir				
Elevation	EL	80.37	m AHD	
Storage Volume		8,531	ML	
Storage Area		229	ha	
Storage Loss	SL	3,257	ML	
Dead Storage Volume	DSV	2,530	ML	
Useable Volume	UV	2,743	ML	
Additional Parameters				
High Priority Allocation	HPA	46,127	ML	
Medium Priority Allocation	MPA	185,732	ML	
Net Total Volume of water allocation moved into current water year	VIWY	49108	ML	Carry Over: 70,182 Forward Draw: 0
Inflow Allowance	IN	0	ML	
Reserve Volume	RE	73,973	ML	

	Abbreviation	Value	Unit	Remarks
Transmission and Operational Losses	TOL	7,013	ML	
Use	USE	0	ML	Carry Over Diversions: 21074

Phone: 13 15 89

Email: customersupport@sunwater.com.au

Visit: www.sunwater.com.au

Page 2 of 2

Delivering water for prosperity