

# Operational Report: Announced Allocation

## Upper Condamine WSS

Effective: 17 February 2020

### IMPORTANT MESSAGE REGARDING WATER AVAILABILITY

In accordance with provisions of Section 6 of the Upper Condamine Water Supply Scheme Operations Manual, the High B and Medium Priority release (cut-off) rule will be activated when Leslie Dam is equal to or below 460.35 m AHD (15,000 ML).

If this rule is activated, Sunwater will be unable to make releases to deliver any unused High B or Medium Priority allocation water, so the below Announced Allocations are not guaranteed.

AA calculated under the ROP	Abbreviation	Value	Unit	Remarks
High Class A Priority AA	AAhpa	100	%	
High Class B Priority AA	AAhpb	100	%	Refer to above message
Medium Priority AA	AAm	20	%	Refer to above message
Risk Class B AA	AArb	N/A	%	
<b>Leslie Dam</b>				
Elevation	EL	461.55	m AHD	
Current Volume	CV	19,403	ML	
Current Area		398	ha	
Storage Loss	SL	2,395	ML	
Minimum Operating Volume	MOV	2,130	ML	
Useable Volume	UV	14,878	ML	
<b>Cecil Plains Weir</b>				
Elevation	EL	352.22	m AHD	
Current Volume	CV	700	ML	
Current Area		34	ha	
Storage Loss	SL	183	ML	
Minimum Operating Volume	MOV	49	ML	
Useable Volume	UV	468	ML	
<b>Additional Parameters</b>				
Diversion	DIV	0	ML	
Diversion for High Priority A	DIV-HPA	760	ML	
Diversion for High Priority B	DIV-HPB	0	ML	
Volume stored in Leslie Dam at SOWY	VOL	10,963	ML	
High Class A Priority Allocation	HPA	3,262	ML	
High Class B Priority Allocation	HPB	125	ML	
Medium Priority Allocation	MPA	22,328	ML	
Reserve Volume	RE	6,000	ML	
Transmission and Operation Allowance	TOAmp	951	ML	
TOA for delivering HPA	TOAhp	0	ML	HPA are on-pond
FSV of Leslie Dam	FSV	106,200	ML	