

# Operational Report: Announced Allocation

## Upper Condamine WSS

Effective: 1 July 2020

### IMPORTANT MESSAGE REGARDING WATER AVAILABILITY

In accordance with provisions of Section 6 of the Upper Condamine Water Supply Scheme Operations Manual, the High B & Medium Priority release (cut-off) rule has been activated as Leslie Dam is below 460.35mAHD (15,005ML).

When the rule is activated, this may impact on Sunwater’s ability to supply all of the announced allocation volume.

AA calculated under the ROP	Abbreviation	Value	Unit	Remarks
High Class A Priority AA	AAhpa	100%	%	
High Class B Priority AA	AAhpb	100%	%	
Medium Priority AA	AAm	0%	%	
Risk Class B AA	AArb	N/A	%	
<b>Leslie Dam</b>				
Elevation	EL	460.04	m AHD	
Current Volume	CV	13,974	ML	
Current Area		320	ha	
Storage Loss	SL	5,297	ML	
Minimum Operating Volume	MOV	2,130	ML	
Useable Volume	UV	6,548	ML	
<b>Cecil Plains Weir</b>				
Elevation	EL	350.52	m AHD	
Current Volume	CV	592	ML	
Current Area		31	ha	
Storage Loss	SL	400	ML	
Minimum Operating Volume	MOV	49	ML	
Useable Volume	UV	144	ML	
<b>Additional Parameters</b>				
Diversion	DIV	0	ML	
Diversion for High Priority A	DIV-HPA	0	ML	
Diversion for High Priority B	DIV-HPB	0	ML	
Volume stored in Leslie Dam at SOWY	VOL	13,974	ML	
High Class A Priority Allocation	HPA	3,262	ML	
High Class B Priority Allocation	HPB	125	ML	
Medium Priority Allocation	MPA	22,328	ML	
Reserve Volume	RE	6,000	ML	
Transmission and Operation Allowance	TOAmp	2,667	ML	
TOA for delivering HPA	TOAhpa	0	ML	HPA are on-pond
FSV of Leslie Dam	FSV	106,200	ML	