

Operational Report: Announced Allocation

Upper Condamine WSS

Effective: 1 July 2024

IMPORTANT MESSAGE REGARDING WATER AVAILABILITY

In accordance with provisions of Section 6 of the Upper Condamine Water Supply Scheme Operations Manual, the High B & Medium Priority release (cut-off) will be activated when Leslie Dam is below 460.35m AHD (15,005 ML).

When the rule is activated, this may impact on Sunwater's ability to supply all the announced allocation volume.

	Abbreviation	Value	Unit	Remarks
High Class A Priority AA	AA _{HPA}	100	%	
High Class B Priority AA	AA _{HPB}	100	%	
Medium Priority AA	AA _{MP}	100	%	
Risk Class B AA	AA _{RB}	0	%	
Leslie Dam				
Elevation	EL	469.69	m AHD	
Current Volume	CV	74,986	ML	
Surface Area	SA	1,016	ha	
Storage Loss	SL	16,841	ML	
Minimum Operating Volume	MOV	2,130	ML	
Useable Volume	UV	56,015	ML	
Cecil Plains Weir				
Elevation	EL	347.51	m AHD	
Current Volume	CV	39	ML	
Surface Area	SA	7	ha	
Storage Loss	SL	39	ML	
Minimum Operating Volume	MOV	49	ML	
Useable Volume	UV	0	ML	
Additional Parameters				
Diversion	DIV	0	ML	
Diversion for High Priority A	DIV _{HPA}	0	ML	
Diversion for High Priority B	DIV _{HPB}	0	ML	
Volume stored in Leslie Dam at SOWY	VOL	74,986	ML	
High Class A Priority Nominal Volume	HPA	3,262	ML	
High Class B Priority Nominal Volume	HPB	125	ML	
Medium Priority Allocation	MPA	22,328	ML	
Reserve Volume	RE	6,000	ML	
Transmission and Operation Allowance (MP)	TOA _{MP}	11,288	ML	
Transmission and Operation Allowance (HP)	TOA _{HPA}	0	ML	HPA are on-pond
Full Supply Volume of Leslie Dam	FSV _{LD}	106,200	ML	